

INSTALLATION GUIDE ENGLISH v1.1

code: ZRS2768GD

Name: RACK cabinet, floor standing, fully assembled 27U/600x800



IM ZRS2768GD

Edition: 3 from 25.02.2016 Supersedes: 2 from 18.10.2013


1. Intended use:

The RACK 19" cabinet enables integrating CCTV, AC, I&HAS, RTV, LAN, or other systems in medium and big companies. It is intended for devices manufactured in enclosures of the 19" standard. Due to the RACK cabinets, the devices are aesthetically mounted and protected against mechanical damage.

2. Specifications:


SPECIFICATIONS	
Mounting dimensions:	W=19", H=27U
External dimensions:	W=600, H=1388, D=800 [mm, +/-2]
Net/gross weight:	74 / 78,9 [kg]
Materials:	- RACK mounting rails: cold-rolled steel SPCC 2mm RAL 9004 - bolted - horizontal mounting rails: cold-rolled steel SPCC 1,5mm RAL 9004 - bolted - frame: cold-rolled steel SPCC 1,2mm RAL 9004 - welded - front door: 5mm toughened glass / SPCC 1,2mm RAL 9004 - hinged - side panels: cold-rolled steel SPCC 1,2mm RAL 9004 - removable - rear door: cold-rolled steel SPCC 1,2mm RAL 9004 - hinged
Static load:	800 kg (with leveling feet)
Use:	inside, IP20
Notes:	- adjustable distance between front and rear RACK rails - ventilation holes in the front door, top and bottom panel - possible mounting of a fan tray in the top panel - RAWP (max. 2 pieces.) - cable ducts in the top and bottom panel - 4 casters without brakes and 4 leveling feet included - possible assembly of a 100mm high plinth - RAC168 - lockable front door (2 keys included) - lockable rear door (2 keys included) - side panels - lock assembly possible - RAZB16 - fully assembled
Certificates, declarations:	RoHS

3. Structure of the cabinet.



EN*





MANUFACTURER Pulsar

Siedlec 150, 32-744 Łapczyca

Tel. 14-610-19-40, Fax. 14-610-19-50 e-mail: biuro@pulsar.pl, sales@pulsar.pl http:// www.pulsar.pl, www.zasilacze.pl

WARRANTY

12 months from the date of purchase. THE WARRANTY IS VALID only upon presentation of the item's proof of purchase.